



TEST REPORT IEC 60998-1 Connecting devices for low voltage circuits for household and similar purposes Part 1: General requirements	
Report Reference No.:	LCS200901099AS
Date of issue:	2020-09-28
Total number of page:	20 pages
Applicant's name:	Shenzhen Onlumi Technology Limited
Address:	Room 218, 2F, Building D, YouDingQiChuang Area, NO.62, Heping Road, Qinghua Community, Longhua District, Shenzhen, G.D., China
Test specification:	
Standard:	IEC 60998-1:2002
Test procedure:	CE-LVD
Non-standard test method:	N/A
Test Report Form No.:	IEC60998_1
Test Report Form(s) Originator:	DEKRA certification B.V.
Master TRF:	Dated 2013-02
Copyright © 2013 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
Test item description:	Solid Lock LED Strip Connector
Trade Mark:	QIJIE
Manufacturer:	Shenzhen QIJIE Electronic Co., LTD.
Address:	5F, 21th, Chuangye Road, Shilong Community, Shiyan, BaoAn, Shenzhen, Guangdong, China
Model/Type reference:	See models list
Ratings:	See models list





TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | [http:// www.lcs-cert.com](http://www.lcs-cert.com)




Testing procedure and testing location:		
<input checked="" type="checkbox"/>	Testing Laboratory:	Shenzhen LCS Compliance Testing Laboratory Ltd.
Testing location/ address		Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tested by		Uic Wan / Test Engineer 
Checked by		Albert Lai / Project Engineer 
Approved by		Hart Qiu / Project Manager 
		
List of Attachments (including a total number of pages in each attachment):		
Attachment No.1: Photo documentation (4 pages)		
Summary of testing:		
Tests performed (name of test and test clause): The submitted samples were found to comply with the requirements of: ➤ Electrical safety IEC 60998-1:2002 EN 60998-1:2004		Testing location: Shenzhen LCS Compliance Testing Laboratory Ltd. Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Summary of compliance with National Differences		
List of countries addressed: <input checked="" type="checkbox"/> The product have evaluated the requirements of EN 60998-1:2004.		

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | http:// www.lcs-cert.com

**Copy of marking plate:****The artwork below may be only a draft.****Remark:**

- 1) Representative markings of model: SL10XB-2W, markings of all models are identical except for model names.
- 2) The height dimension of CE mark should not less than 5mm.

**Test item particulars:**Number of terminals.....: ☒single ☐multiwayProtection against electric shock.....: ☐with ☐withoutMeans of fixing.....: ☒with ☐withoutRated temperature.....: ☒without T marking ☐with T marking (°C)

IP number.....: IPX0

Type of terminals, screwless-type.....: ☐universal ☒non-universal ☐push wireConductor type.....: ☐rigid ☒flexibleRated connecting capacity.....: ☒0,5mm² ☐0,75mm² ☐1mm² ☐1,5mm²
☐2,5mm² ☐4mm² ☐6mm² ☐10mm²Conductor insulation.....: ☐16mm² ☐25mm² ☐35 mm²Rated voltage (V ac / V dc).....: ☐AC ☒DC

Classification of installation and use.....: single way terminal devices

Supply Connection: Screwless-type terminal

Possible test case verdicts:

- test case does not apply to the test object.....: N/A

- test object does meet the requirement.....: P (Pass)

- test object does not meet the requirement.....: F (Fail)

Testing.....:

Date of receipt of test item: 2020-09-09

Date (s) of performance of tests: From 2020-09-09 to 2020-09-28

General remarks:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a ☐ comma / ☒ point is used as the decimal separator.

**Manufacturer's Declaration per sub-clause 4.2.5 of IEC60998 2_2B:**

The application for obtaining a CB Test Certificate ☐ Yes
includes more than one factory location and a ☒ Not applicable
declaration from the Manufacturer stating that the
sample(s) submitted for evaluation is (are)
representative of the products from each factory
has been provided

When differences exist; they shall be identified in the General product information section.

Name and address of factory (ies) : Same as manufacturer

General product information:

1. All models are similar except for the model name and following parameter, all tests were conducted on model SL10XB-2W.

Models list:

Model name	parameter
SL8XB-2	strip to wire terminal DC3~24V / Max 6A Copper & Nylon
SL10XB-2	
SL10XB-3	
SL10XB-4	
SL8XB-2W	strip to power with strand wire Wire: 15CM 20AWG / 0.5mm ² Black-Red Insulation DC3~24V / Max 6A Copper & Nylon
SL10XB-2W	
SL10XB-3W	strip to power with strand wire Wire: 15CM 20AWG / 0.5mm ² (Max Gauge) Red-White-Yellow Insulation DC3~24V / Max 6A Copper & Nylon
SL10XB-4W	strip to power with strand wire Wire: 15CM 22AWG / 0.3mm ² (Max Gauge) Black-Green-Red-Blue Insulation DC3~24V / Max 4A Copper & Nylon
SL8BB-2	strip to strip joint DC3~24V / Max 6A Copper & Nylon
SL10BB-2	
SL10BB-3	
SL10BB-4	
SL8BXB-2W	strip to strip bridge with strand wire 15CM 20AWG / 0.5mm ² Black&Red Insulation DC3~24V / Max 6A
SL10BXB-2W	
SL10BXB-3W	strip to strip bridge with strand wire 15CM 20AWG / 0.5mm ² (Max Gauge) Red-white-yellow Insulation DC3~24V / Max 6A
SL10BXB-4W	strip to strip bridge with strand wire Wire: 15CM 22AWG / 0.3mm ² (Max Gauge) Black-Green-Red-Blue Insulation DC3~24V / Max 4A Copper & Nylon

TRF No. IEC60998 2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | <http://www.lcs-cert.com>



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

8	MARKING		P
8.1	On main part:		P
	a) rated connecting capacity (mm ²)	0.3-0.5	P
	b) rated insulation voltage (V)	3-24Vd.c.	P
	c) T marking (°C) (if > 40 °C or < -5 °C)		N/A
	d) type reference	See page 1	P
	e) manufacturer's or responsible vendor's name, trademark or identification mark.....	See page 1	P
	f) IP if > IP20		N/A
	Small devices: only d) and e) indicated on device		N/A
	All marks visible on smallest package unit		N/A
8.101	Type of acceptable conductor "s" "r" or "f"		N/A
8.102	Marking indicating the length of insulation to be removed before insertion of the conductor		P
8.2	Multiway terminal devices: at least two adjacent		N/A
8.3	When symbols are used they shall be as follow: V for volts mm ² or □ for square millimetres T for T-rating		N/A
8.4	Marking: durable and easily legible; 15 s water; 15 s hexane		P

9	PROTECTION AGAINST ELECTRIC SHOCK		P
	Live parts not accessible		P

10	CONNECTION OF CONDUCTORS		P
10.1	Connecting devices allow correct connection of conductors		P
10.101	Connection or disconnection: use a general tool or simple insertion		P
	Disconnection operation other than a pull		P
10.102	Terminals accept two or more conductors of same or different nominal cross-sectional areas; see table 101 (as specified by manufacturer):		P
	Universal terminals shall accept rigid(solid or stranded) and flexible unprepared conductors		P

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | http:// www.lcs-cert.com



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Non-universal terminals shall accept the types of conductors declared by the manufacturer		N/A
	Rated connecting capacity (mm ²)	0.3-0.5 mm ²	P
	Suitable for connecting cross-sectional areas (mm ²)	Rigid and/or flexible conductor of 0.3 mm ² (for connecting capacity: 0.3 mm ²); Rigid and/or flexible conductor of 0.5 mm ² (for connecting capacity: 0.5 mm ²)	P
10.103	Terminals accept rigid and flexible conductors (table 101), unless otherwise specified (see 8.1)		P
	Smallest diameter (mm); largest diameter (mm).... :	Rigid solid conductor: 0.63, rigid Stranded conductor: 0.66, flexible conductor: 0.8 (for connecting capacity: 0.3 mm ²); Rigid solid conductor: 0.9, rigid Stranded conductor: 1.1, flexible conductor: 1.1 (for connecting capacity: 0.5 mm ²)	P
	During the test: terminals show no damage		P
10.104	Terminals clamp the conductor without undue damage:		P
10.104.1	Connection/disconnection 5 times: smallest diameter (mm)..... :	rigid conductor: 0.63 (for connecting capacity: 0.3 mm ²); rigid conductor: 0.9 (for connecting capacity: 0.5 mm ²)	P
	Connection/disconnection 5 times: largest diameter (mm)..... :	flexible conductor: 0.8 (for connecting capacity: 0.3 mm ²); flexible conductor: 1.1 (for connecting capacity: 0.5 mm ²)	P
	After the test, terminal not damaged		P
10.104.2	Rated cross-sectional area (mm ²)	0.3-0.5	P

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | http:// www.lcs-cert.com



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

	Type	Rigid and flexible	P
	After the test, no wire of conductor escaped outside the terminal		P
10.105	Secureness test:		P
	during the test: the conductor does not slip out, no break near clamping unit and no damage	See appended table 10.105	P
10.106	Pull test:		P
	- during the test the conductor does not come out	See appended table 10.106	P

11	CONSTRUCTION		P
11.101	Contact pressure not transmitted via insulating material, unless there is sufficient resiliency		P
11.102	Insertion and disconnection, in accordance with manufacturer's instructions		P
	Openings clearly distinguishable		P
11.103	Terminals so constructed that:		P
	- each conductor is clamped individually		P
	- conductors can be connected or disconnected at same time or separately		P
	Possible to clamp maximum number of conductors		P
11.104	Inadequate insertion of conductor avoided		P
11.2	Clamping units clamp conductors reliably and between metal surfaces		P
11.3	Connecting devices: insulation of conductors not in contact with live parts of different polarity		P
11.4	Insulating lining: adequate mechanical strength and secured in a reliable manner		P
11.5	Current-carrying parts: adequate mechanical strength, electrical conductivity and resistance to corrosion; type of metal		P
	Current-carrying parts not made with electroplated coating if subjected to mechanical wear		P
11.6	Terminals: possible to connect number of conductors as specified by the manufacturer:		P
	- number of conductors		P

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | [http:// www.lcs-cert.com](http://www.lcs-cert.com)



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
	- rigid, cross-sectional area (mm ²)	0.3 mm ² (for connecting capacity: 0.3 mm ²); 0.5 mm ² (for connecting capacity: 0.5 mm ²)	P
	- flexible, cross-sectional area (mm ²).....	0.3 mm ² (for connecting capacity: 0.3 mm ²); 0.5 mm ² (for connecting capacity: 0.5 mm ²)	P
11.7	Fixing means of bases do not serve any other purpose		P
12	RESISTANCE TO AGEING, TO HUMIDITY CONDITIONS, TO INGRESS OF SOLID OBJECTS AND TO HARMFUL INGRESS OF WATER		P
12.1	Connecting devices resistant to ageing; after the test (168 h): no cracks visible, not sticky or greasy, no damage; test temperature (°C)	<input checked="" type="checkbox"/> 70 °C <input type="checkbox"/> T + 30 °C =	P
12.2	After humidity test (91-95%): no damage; test duration (168 h for connecting devices > IPx2, 48 h for all other).....	<input type="checkbox"/> 168 h <input checked="" type="checkbox"/> 48 h	P
12.3	IP test (IEC 60529).....	IP__	N/A
	After the test, electric strength test as 13.4, and by inspection	IP__	N/A
	no appreciable entry of water		N/A
13	INSULATION RESISTANCE AND ELECTRIC STRENGTH		P
13.1	Insulated connecting devices provided with adequate insulation resistance and electric strength		P
13.2	Insulation between the connected conductors and the external surface is adequate for all the combinations of conductors		P
13.3	Insulation resistance measured 1 min after application of 500 V d.c.	See appended table 13.3	P
13.4	Electric strength test	See appended table 13.4	P



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

14	MECHANICAL STRENGTH		P
14.101	the test conductor, properly inserted into a clamping unit of the connection devices shall be allowed to be bent (deflected) in all 12 directions each of them differing from the adjacent directions by $30^\circ \pm 5^\circ$		P
	Deflection test (principle of test apparatus shown in figure 103a):		P
	- requirement: $\leq 2,5$ mV	See appended table 14.101	P
	max measured voltage drop (mV)		P
14.2	Tumbling barrel (for < 50 g): 50 falls; after the test no damage		P
14.3	Impact test (for > 50 g): 10 blows:		N/A
	- height of fall: 7,5 cm		N/A
	- height of fall: 10 cm		N/A
	- height of fall: 20 cm		N/A
	- height of fall: 25 cm		N/A
	After the test, no damage and live parts shall not become accessible		N/A

15	TEMPERATURE RISE		P
	requirement: ≤ 45 K		P
	max measured temperature rise (K)	See appended table 15	P
15.101	192 temperature cycles test, each cycle with a duration of 1 h, with the test current as defined in Table 2 of Part I		P
	Cabinet temperature ($^\circ\text{C}$)..... :	<input checked="" type="checkbox"/> 40 <input type="checkbox"/> T-marking: .. $^\circ\text{C}$	P
	Maximum voltage drop did not exceed 22,5 mV or 1,5 times 24 th cycle value	See appended table 15.101	P

16	RESISTANCE TO HEAT		P
16.1	Connecting devices are sufficiently resistant to heat		P
16.2	Heating cabinet test	See appended table 16.2	P
	After the test: no changes impairing further use and markings still legible		P
16.3	Ball-pressure test (IEC 60695-10-2) for parts necessary to retain current-carrying parts and parts of the earthing circuit in position	See appended table 16.3A	P

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | [http:// www.lcs-cert.com](http://www.lcs-cert.com)



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Impression diameter not exceed 2 mm		P
	Ball-pressure test (IEC 60695-10-2) for parts not necessary to retain current-carrying parts and parts of the earthing circuit in position	See appended table 16.3B	P
	Impression diameter not exceed 2 mm		P
17	CLEARANCES AND CREEPAGE DISTANCES		N/A
	Creepage distances, clearances and distances through sealing compound	just a terminal depends to the covers	N/A
18	RESISTANCE OF INSULATING MATERIAL TO ABNORMAL HEAT AND FIRE		P
	Glow-wire test (clauses 4 to 10 of IEC 60695-2-10)	See appended table 18	P
	No visible flames and no sustained glowing or flame and glowing extinguished within 30 s		P
	No ignition of the tissue paper or scorching of the board		P
19	RESISTANCE OF INSULATING MATERIAL TO TRACKING		P
	Tracking test (IEC 60112): PTI 175 V, 50 drops, solution A	See appended table 19	P

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | <http://www.lcs-cert.com>



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

10.105	TABLE: Clamping securement and damage to the conductor test					P
	Model/type reference.....:					P
No of sample	Conductor cross-sectional area (mm²)	Conductor type	Mass for conductor (kg)	Height H (mm)	Diameter of bushing hole (mm)	
1	0.3	Rigid / Flexible	0.2	260	6.4	P
2	0.3	Rigid / Flexible	0.2	260	6.4	P
3	0.3	Rigid / Flexible	0.2	260	6.4	P
4	0.5	Rigid / Flexible	0.3	260	6.5	P
5	0.5	Rigid / Flexible	0.3	260	6.5	P
6	0.5	Rigid / Flexible	0.3	260	6.5	P
Supplementary information:						

10.106	TABLE: Pull-out test					P
	Model/type reference.....:					P
No of sample	Conductor cross-sectional area (mm²)	Conductor type		Pull force (N)		
1	0.3	Rigid / Flexible		15		P
2	0.3	Rigid / Flexible		15		P
3	0.3	Rigid / Flexible		15		P
4	0.5	Rigid / Flexible		20		P
5	0.5	Rigid / Flexible		20		P
6	0.5	Rigid / Flexible		20		P
Supplementary information:						

13.3	TABLE: Insulation resistance		P
	Model/type reference.....:		--
	Smallest cross-sectional area (mm ²) :	0.3	--
	Largest cross-sectional area (mm ²) :	0.5	--
Test voltage applied between		Measured (MΩ)	Required (MΩ)
All clamping units together and the body		>100MΩ	≥5MΩ

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | http:// www.lcs-cert.com



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

Each clamping unit and all others together	>100MΩ	≥5MΩ	
Supplementary information:			

13.4	TABLE: Electric strength test			P
	Model/type reference.....:			P
	Rated insulation voltage (V).....:	24		P
Test voltage applied between		Test voltage (V)	Flashover / breakdown (Yes/No)	
All clamping units together and the body		1250	No	
Each clamping unit and all others together		1250	No	
Supplementary information:				

14.101	TABLE: Mechanical strength				P
	0,1 times the test current (A)..... :	--			--
	smallest cross-sectional area (mm²) 10.103 :	0.5			--
	force (N) (table 104) :	0.09			--
	Distance (mm) (table 104) :	100			--
	-screwless terminal number	1	2	3	--
	- voltage drop measured (mV) (1 st deflection) :	0.5	0.6	0.6	--
	- voltage drop measured (mV) (2 nd deflection) :	0.6	0.6	0.7	--
	- voltage drop measured (mV) (3 rd deflection) :	0.6	0.6	0.7	--
	- voltage drop measured (mV) (4 th deflection) :	0.7	0.7	0.7	--
	- voltage drop measured (mV) (5 th deflection) :	0.7	0.8	0.8	--
	- voltage drop measured (mV) (6 th deflection) :	0.9	0.9	0.9	--
	- voltage drop measured (mV) (7 th deflection) :	1.0	1.2	1.0	--
	- voltage drop measured (mV) (8 th deflection) :	1.0	1.2	1.1	--
	- voltage drop measured (mV) (9 th deflection) :	1.1	1.3	1.1	--
	- voltage drop measured (mV) (10 th deflection) :	1.1	1.3	1.1	--
	- voltage drop measured (mV) (11 th deflection) :	1.2	1.4	1.2	--
	- voltage drop measured (mV) (12 th deflection) :	1.2	1.4	1.2	--
	- requirement: ≤ 2,5 mV				--

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | http:// www.lcs-cert.com



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict
15	TABLE: Temperature rise		P
	Model/type reference.....:		P
	Terminal.....:	<input checked="" type="checkbox"/> single <input type="checkbox"/> multiway	—
	T marking (°C).....:	<input type="checkbox"/> Yes (..°C):	—
	Largest cross-sectional area (mm ²).....:	0.5	—
	Conductors	Rigid / Flexible	—
	Rated connecting capacity (mm ²).....:	0.3-0.5	—
	Test current (A)	6A	—
Thermocouple Locations		max. temperature measured, (°C)	max. temperature limit, (°C)
On conductor in the terminal		21.0	45
wire		12.3	45
Supplementary information:			

15.101	TABLE: Temperature-cycling test			P	
	Model/type reference			P	
	Smallest cross-sectional area (mm ²)	0.5		P	
	Test current (Table 2) (A)	6		P	
Measured voltage drop of:		Measured voltage drop (mV)			
		Sample 1	Sample 2	Sample 3	
Solid conductors (after 24 cycles)		9.4	10.2	9.8	P
Stranded conductors (after 24 cycles)		10.6	11.3	9.8	P
Flexible conductors (after 24 cycles)		10.9	11.8	9.8	P
Solid conductors (1,5 times 24 th cycle value)		12.7	13.6	14.8	P
Stranded conductors (1,5 times 24 th cycle value)		13.9	14.1	16.9	P
Flexible conductors (1,5 times 24 th cycle value)		14.0	14.2	16.7	P
Solid conductors (after 192 cycles)		15.9	14.7	17.5	P
Stranded conductors (after 192 cycles)		17.6	16.5	19.4	P
Flexible conductors (after 192 cycles)		17.8	16.9	19.2	P
Supplementary information:					

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | http:// www.lcs-cert.com



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

16.2	TABLE: Heating cabinet test			P
	Test temperature (°C)..... :	<input checked="" type="checkbox"/> 85°C	<input type="checkbox"/> T + 45	P
	Model/type reference	Sample 1	Sample 2	Sample 3
	--	Pass	Pass	Pass
Supplementary information:				

16.3A	TABLE: Ball pressure test of insulating materials			P
	Test temperature (°C)..... :	<input checked="" type="checkbox"/> 125	<input type="checkbox"/> T + 45 =	P
	Part under test	Material designation / manufacturer	Impression diameter (mm)	
	Terminal	/	1.0	P
Supplementary information:				

16.3B	TABLE: Ball pressure test of insulating materials			N/A
	Test temperature (°C)..... :	<input checked="" type="checkbox"/> 70	<input type="checkbox"/> T + 40 =	N/A
	Part under test	Material designation / manufacturer	Impression diameter (mm)	
	--	--	--	N/A
Supplementary information:				

17	TABLE: Clearances and creepage distances				N/A
	Rated insulation voltage (V)..... :	30			N/A
	Clearance cl, creepage distance cr and distance through sealing compound tsc at/of:	Required cl, cr, tsc (mm)	Measured cl (mm)	Measured cr (mm)	Measured tsc (mm)
	Between clamping units	≥3.0	--	≥3.0	--
	Contacts-Plastic material	≥3.0	--	≥3.0	--
Supplementary information:					

18	TABLE: Glow-wire test			P
	Part under test	Material designation / manufacturer	Test temperature (°C)	Time of extinguish of flames and glowing, if any
	Terminal	/	750	flame extinguished immediately after removal.

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | http://www.lcs-cert.com



IEC 60998-2-2			
Clause	Requirement + Test	Result - Remark	Verdict

Supplementary information:

19	TABLE: Tracking			P
Part under test		Material designation / manufacturer	Test voltage (V)	Remarks
Terminal		/	175	Pass
Supplementary information:				

APPENDED TABLE					
Critical components					
Object / part no.	Manufacturer / trademark	Type / model	Technical data	Standard	Mark(s) of Conformity
Terminal	/	/	PC	/	/
wire	/	/		/	/

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.


Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | [http:// www.lcs-cert.com](http://www.lcs-cert.com)




Attachment No. 1: photo documentation

Details of: External view



Details of: External view



TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.


Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | [http:// www.lcs-cert.com](http://www.lcs-cert.com)




Attachment No. 1: photo documentation

Details of: External view



Details of: External view



TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.


Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | [http:// www.lcs-cert.com](http://www.lcs-cert.com)




Attachment No. 1: photo documentation

Details of: External view



Details of: External view



TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.


Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | [http:// www.lcs-cert.com](http://www.lcs-cert.com)




Attachment No. 1: photo documentation

Details of: External view



Details of: External view



--- END OF REPORT ---

TRF No. IEC60998_2_2B

Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86)755-82591330 | Fax: +(86)755-82591332 | E-mail: webmaster@lcs-cert.com | [http:// www.lcs-cert.com](http://www.lcs-cert.com)