




TEST REPORT IEC 60998-1 Connecting devices for low voltage circuits for household and similar purposes Part 1: General requirements	
Report Reference No.	LCSA03105330S
Date of issue	2025-04-03
Total number of page	21 pages
Applicant's name	Shenzhen Onlumi Technology Limited
Address	Room 218, 2F, Building D, YouDingQiChuang Area, NO. 62, HePing Road, QingHua Community, LongHua District, Shenzhen, G. D. China
Test specification:	
Standard	IEC 60998-1:2002
Test procedure	Type test
Non-standard test method	N/A
Test item description	Hippo-M MAX LED Strip Connector
Trade Mark	
Manufacturer	Same as the applicant
Model/Type reference	See model list
Ratings	See model list

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity




Testing procedure and testing location:		
<input checked="" type="checkbox"/>	Testing Laboratory:	Shenzhen LCS Compliance Testing Laboratory Ltd.
Testing location/ address.....:		Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tested by.....:		Angus Lu/ Test engineer <i>Angus Lu</i>
Checked by.....:		Tim Liu / Project engineer <i>Tim-Liu</i>
Approved by.....:		Hart Qiu / Technical manager <i>Hart Qiu</i>
List of Attachments (including a total number of pages in each attachment): Attachment No.1: Photo documentation		
Summary of testing:		
Tests performed (name of test and test clause): The submitted samples were found to comply with the requirements of: ➢ Electrical safety ➢ IEC 60998-1:2002 EN 60998-1:2004		Testing location: Shenzhen LCS Compliance Testing Laboratory Ltd. Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity

**Copy of marking plate:****The artwork below may be only a draft.****Remark:**

- 1) Minimum height of CE mark is 5mm, minimum height of WEEE mark is 7mm.
- 2) Name and address of the Importer and Manufacturer must be affixed on the product when the product placed on the EU market.

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street,
Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity

**Test item particulars:**Number of terminals.....: ☐ single ☒ multiwayProtection against electric shock.....: ☐ with ☒ withoutMeans of fixing.....: ☒ with ☐ withoutRated temperature.....: ☒ without T marking ☐ with T marking (°C)

IP number.....: IPX0

Type of terminals, screwless-type.....: ☐ universal ☐ non-universal ☒ push wireConductor type.....: ☒ rigid ☐ flexibleRated connecting capacity.....: ☐ 0,34mm² ☒ 0,5mm² ☐ 0,75mm² ☐ 1mm²Conductor insulation.....: ☐ 1,5mm² ☐ 2,5mm² ☐ 4mm² ☐ 6mm²
☐ 10mm² ☐ 16mm² ☐ 25mm² ☐ 35 mm²Rated voltage (V ac / V dc).....: ☐ AC ☒ DC

Classification of installation and use.....: multiway terminal devices

Supply Connection.....: DC terminal

Possible test case verdicts:

- test case does not apply to the test object.....: N/A

- test object does meet the requirement.....: P (Pass)

- test object does not meet the requirement.....: F (Fail)

Testing.....:

Date of receipt of test item.....: 2025-03-10

Date (s) of performance of tests.....: From 2025-03-10 to 2025-04-03

General remarks:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a ☐ comma / ☒ point is used as the decimal separator.

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com

Scan code to check authenticity

**Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60950-1:**

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided..... : ☐ Yes ☒ Not applicable

When differences exist; they shall be identified in the General product information section.

Name and address of factory (ies)..... : Same as the applicant

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street,
Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity

**General product information:**

1. The samples for each group of testing were selected randomly from the samples provided by the manufacturer.
2. Tests are conducted on model MX/2045-X10C-2P to represent the other.
3. All models have the same components, internal construction and shape, except for the different model names and trademark, detail refer to model list.

Model	Rated
MX/2045-X5C-2P	DC24V / 5.5A 20AWG(0.5mm ²)
MX/2045-B5C-2P	
MX/2045-X5-3P	
MX/2045-B5-3P	
MX/2045-X8C-2P	
MX/2045-B8C-2P	
MX/2045-X8-3P	
MX/2045-B8-3P	
MX/2045-X8C-3P	
MX/2045-B8C-3P	
MX/2045-X8-4P	
MX/2045-B8-4P	
MX/2045-X8C-4P	
MX/2045-B8C-4P	
MX/2045-X10C-2P	
MX/2045-B10C-2P	
MX/2045-X10-3P	
MX/2045-B10-3P	
MX/2045-X10C-3P	
MX/2045-B10C-3P	
MX/2045-X10-4P	
MX/2045-B10-4P	
MX/2045-X10C-4P	
MX/2045-B10C-4P	
MX/2045-X10-5P	
MX/2045-B10-5P	
MX/2045-X12C-2P	
MX/2045-B12C-2P	
MX/2045-X12-3P	
MX/2045-B12-3P	
MX/2045-X12C-3P	
MX/2045-B12C-3P	

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com

Scan code to check authenticity



MX/2045-X12-4P		
MX/2045-B12-4P		
MX/2045-X12C-4P		
MX/2045-B12C-4P		
MX/2045-X12-5P		
MX/2045-B12-5P		
MX/2045-X12C-5P		
MX/2045-B12C-5		
,MX/2045-X12-6P		
MX/2045-B12-6P		
MX/2045-X12C-6P		
MX/2045-B12C-6P		
MX/2045-X8TC-2P		
MX/2045-B8TC-2P		
MX/2045-X10TC-2P		
MX/2045-B10TC-2P		
MX/2045-X5C-2P/L=150MM		
MX/2045-2X5C-2P/L=150MM		
MX/2045-X5-3P/L=150MM		
MX/2045-2X5-3P/L=150MM		
MX/2045-X8C-2P/L=150MM		
MX/2045-2X8C-2P/L=150MM		
MX/2045-X8-3P/L=150MM		
MX/2045-2X8-3P/L=150MM		
MX/2045-X8C-3P/L=150MM		
MX/2045-2X8C-3P/L=150MM		
MX/2045-X8-4P/L=150MM		
MX/2045-2X8-4P/L=150MM		
MX/2045-X8C-4P/L=150MM		
MX/2045-2X8C-4P/L=150MM		
MX/2045-X10C-2P/L=150MM		
MX/2045-2X10C-2P/L=150MM		
MX/2045-X10-3P/L=150MM		
MX/2045-2X10-3P/L=150MM		
MX/2045-X10C-3P/L=150MM		
MX/2045-2X10C-3P/L=150MM		
MX/2045-X10-4P/L=150MM		
MX/2045-2X10-4P/L=150MM		

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street,
Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



MX/2045-X10C-4P/L=150MM	DC24V / 5.5A 20AWG(0.5mm ²)	
MX/2045-2X10C-4P/L=150MM		
MX/2045-X10-5P/L=150MM		
MX/2045-2X10-5P/L=150MM		
MX/2045-X12C-2P/L=150MM		
MX/2045-2X12C-2P/L=150MM		
MX/2045-X12-3P/L=150MM		
MX/2045-2X12-3P/L=150MM		
MX/2045-X12C-3P/L=150MM		
MX/2045-2X12C-3P/L=150MM		
MX/2045-X12-4P/L=150MM		
MX/2045-2X12-4P/L=150MM		
MX/2045-X12C-4P/L=150MM		
MX/2045-2X12C-4P/L=150MM		
MX/2045-X12-5P/L=150MM		
MX/2045-2X12-5P/L=150MM		
MX/2045-X12C-5P/L=150MM		
MX/2045-2X12C-5P/L=150MM		
MX/2045-X12-6P/L=150MM		
MX/2045-2X12-6P/L=150MM		
MX/2045-X12C-6P/L=150MM		
MX/2045-2X12C-6P/L=150MM		
MX/2045-B5LC-2P		
MX/2045-B5L-3P		
MX/2045-B8LC -2P		
MX/2045-B8L-3P		
MX/2045-B8LC-3P		
MX/2045-B8L-4P		
MX/2045-B8LC-4P		
MX/2045-B10LC-2P		
MX/2045-B10L-3P		
MX/2045-B10LC-3P		
MX/2045-B10L-4P		
MX/2045-B10LC-4P		
MX/2045-B10L-5P		
MX/2045-B10LC-5P		
MX/2045-B12LC-2P		
MX/2045-B12L-3P		

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street,
Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



MX/2045-B12LC-3P		
MX/2045-B12L-4P		
MX/2045-B12LC-4P		
MX/2045-B12L-5P		
MX/2045-B12LC-5P		
MX/2045-B12L-6P		
MX/2045-B12LC-6P		
MX/2045-X5C-2PA		
MX/2045-X8C-2PA		
MX/2045-X10C-2PA		
MX/2045-X12C-2PA		
MX/2045-X5C-2PA/L=150MM		
MX/2045-X8C-2PA/L=150MM		
MX/2045-X10C-2PA/L=150MM		
MX/2045-X12C-2PA/L=150MM		
MX/2045-2X5C-2PA/L=150MM		
MX/2045-2X8C-2PA/L=150MM		
MX/2045-2X10C-2PA/L=150MM		
MX/2045-2X12C-2PA/L=150MM		

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street,
Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



IEC 60998-1			
Clause	Requirement + Test	Result - Remark	Verdict

8	MARKING		P
8.1	On main part:		P
	a) rated connecting capacity (mm ²)..... :	See label	P
	b) rated insulation voltage (V)..... :	See label	P
	c) T marking (°C) (if > 40 °C or < -5 °C)..... :		N/A
	d) type reference..... :	See label	P
	e) manufacturer's or responsible vendor's name, trademark or identification mark..... :	See label	P
	f) IP if > IP20..... :		N/A
	Small devices: only d) and e) indicated on device		N/A
	All marks visible on smallest package unit		P
8.101	Type of acceptable conductor "s" "r" or "f"	See label	P
8.102	Marking indicating the length of insulation to be removed before insertion of the conductor		N/A
8.2	Multiway terminal devices: at least two adjacent		P
8.3	When symbols are used they shall be as follow: V for volts mm ² or □ for square millimetres T for T-rating		P
8.4	Marking: durable and easily legible; 15 s water; 15 s hexane		P

9	PROTECTION AGAINST ELECTRIC SHOCK		P
	Live parts not accessible		P

10	CONNECTION OF CONDUCTORS		P
10.1	Connecting devices allow correct connection of conductors		P
10.101	Connection or disconnection: use a general tool or simple insertion		P
	Disconnection operation other than a pull		P
10.102	Terminals accept two or more conductors of same or different nominal cross-sectional areas; see table 101 (as specified by manufacturer):		P

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



IEC 60998-1			
Clause	Requirement + Test	Result - Remark	Verdict

	Universal terminals shall accept rigid(solid or stranded) and flexible unprepared conductors		N/A
	Non-universal terminals shall accept the types of conductors declared by the manufacturer		P
	Rated connecting capacity (mm ²)..... :	0.5	P
	Suitable for connecting cross-sectional areas (mm ²):	Rigid and/or flexible conductor of 0.5 mm ² (for connecting capacity: 0.5mm ²);	P
10.103	Terminals accept rigid and flexible conductors (table 101), unless otherwise specified (see 8.1)		P
	Smallest diameter (mm); largest diameter (mm).....:	Rigid solid conductor: 0.9, rigid Stranded conductor: 1.1, flexible conductor: 1.1(for connecting capacity: 0.5 mm ²);	P
	During the test: terminals show no damage		P
10.104	Terminals clamp the conductor without undue damage:		P
10.104.1	Connection/disconnection 5 times: smallest diameter (mm).....:		N/A
	Connection/disconnection 5 times: largest diameter (mm).....:		P
	After the test, terminal not damaged		P
10.104.2	Rated cross-sectional area (mm ²).....:	0.5	P
	Type.....:	Rigid and flexible	P
	After the test, no wire of conductor escaped outside the terminal		P
10.105	Secureness test:		P
	during the test: the conductor does not slip out, no break near clamping unit and no damage	See appended table 10.105	P
10.106	Pull test:		P
	- during the test the conductor does not come out	See appended table 10.106	P

11	CONSTRUCTION		P
11.101	Contact pressure not transmitted via insulating material, unless there is sufficient resiliency		P

TRF-4-S-077 A/O



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



IEC 60998-1			
Clause	Requirement + Test	Result - Remark	Verdict
11.102	Insertion and disconnection, in accordance with manufacturer's instructions		P
	Openings clearly distinguishable		P
11.103	Terminals so constructed that:		P
	- each conductor is clamped individually		P
	- conductors can be connected or disconnected at same time or separately		P
	Possible to clamp maximum number of conductors		P
11.104	Inadequate insertion of conductor avoided		P
11.2	Clamping units clamp conductors reliably and between metal surfaces		P
11.3	Connecting devices: insulation of conductors not in contact with live parts of different polarity		P
11.4	Insulating lining: adequate mechanical strength and secured in a reliable manner		P
11.5	Current-carrying parts: adequate mechanical strength, electrical conductivity and resistance to corrosion; type of metal..... :		P
	Current-carrying parts not made with electroplated coating if subjected to mechanical wear		P
11.6	Terminals: possible to connect number of conductors as specified by the manufacturer:		P
	- number of conductors..... :		P
	- rigid, cross-sectional area (mm ²)..... :	0.5	P
	- flexible, cross-sectional area (mm ²)..... :		N/A
11.7	Fixing means of bases do not serve any other purpose		P
12	RESISTANCE TO AGEING, TO HUMIDITY CONDITIONS, TO INGRESS OF SOLID OBJECTS AND TO HARMFUL INGRESS OF WATER		P
12.1	Connecting devices resistant to ageing; after the test (168 h): no cracks visible, not sticky or greasy, no damage; test temperature (°C)..... :	<input checked="" type="checkbox"/> 70 °C <input type="checkbox"/> T + 30 °C =	P
12.2	After humidity test (91-95%): no damage; test duration (168 h for connecting devices > IPx2, 48 h for all other)..... :	<input type="checkbox"/> 168 h <input checked="" type="checkbox"/> 48 h	P

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



IEC 60998-1			
Clause	Requirement + Test	Result - Remark	Verdict
12.3	IP test (IEC 60529)..... :	IP__	N/A
	After the test, electric strength test as 13.4, and by inspection	IP__	N/A
	no appreciable entry of water		N/A
13	INSULATION RESISTANCE AND ELECTRIC STRENGTH		P
13.1	Insulated connecting devices provided with adequate insulation resistance and electric strength		P
13.2	Insulation between the connected conductors and the external surface is adequate for all the combinations of conductors		P
13.3	Insulation resistance measured 1 min after application of 500 V d.c.	See appended table 13.3	P
13.4	Electric strength test	See appended table 13.4	P
14	MECHANICAL STRENGTH		P
14.101	the test conductor, properly inserted into a clamping unit of the connection devices shall be allowed to be bent (deflected) in all 12 directions each of them differing from the adjacent directions by $30^\circ \pm 5^\circ$		P
	Deflection test (principle of test apparatus shown in figure 103a):		P
	- requirement: $\leq 2,5$ mV	See appended table 14.101	P
	max measured voltage drop (mV)		P
14.2	Tumbling barrel (for < 50 g): 50 falls; after the test no damage		P
14.3	Impact test (for > 50 g): 10 blows:		N/A
	- height of fall: 7,5 cm		N/A
	- height of fall: 10 cm		N/A
	- height of fall: 20 cm		N/A
	- height of fall: 25 cm		N/A
	After the test, no damage and live parts shall not become accessible		N/A
15	TEMPERATURE RISE		P
	requirement: ≤ 45 K		P

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



IEC 60998-1			
Clause	Requirement + Test	Result - Remark	Verdict
	max measured temperature rise (K)	See appended table 15	P
15.101	192 temperature cycles test, each cycle with a duration of 1 h, with the test current as defined in Table 2 of Part I		P
	Cabinet temperature (°C).....:	<input checked="" type="checkbox"/> 40 <input type="checkbox"/> T-marking: 80°C	P
	Maximum voltage drop did not exceed 22,5 mV or 1,5 times 24 th cycle value	See appended table 15.101	P
16	RESISTANCE TO HEAT		P
16.1	Connecting devices are sufficiently resistant to heat		P
16.2	Heating cabinet test	See appended table 16.2	P
	After the test: no changes impairing further use and markings still legible		P
16.3	Ball-pressure test (IEC 60695-10-2) for parts necessary to retain current-carrying parts and parts of the earthing circuit in position	See appended table 16.3A	P
	Impression diameter not exceed 2 mm		P
	Ball-pressure test (IEC 60695-10-2) for parts not necessary to retain current-carrying parts and parts of the earthing circuit in position	See appended table 16.3B	N/A
	Impression diameter not exceed 2 mm		N/A
17	CLEARANCES AND CREEPAGE DISTANCES		P
	Creepage distances, clearances and distances through sealing compound		P
18	RESISTANCE OF INSULATING MATERIAL TO ABNORMAL HEAT AND FIRE		P
	Glow-wire test (clauses 4 to 10 of IEC 60695-2-10)	See appended table 18	P
	No visible flames and no sustained glowing or flame and glowing extinguished within 30 s		P
	No ignition of the tissue paper or scorching of the board		P
19	RESISTANCE OF INSULATING MATERIAL TO TRACKING		P
	Tracking test (IEC 60112): PTI 175 V, 50 drops, solution A	See appended table 19	P

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



IEC 60998-1			
Clause	Requirement + Test	Result - Remark	Verdict

10.105	TABLE: Clamping securement and damage to the conductor test					P
	Model/type reference.....:					P
No of sample	Conductor cross-sectional area (mm ²)	Conductor type	Mass for conductor (kg)	Height H (mm)	Diameter of bushing hole (mm)	
1	0.5	Rigid	0.3	260	6.5	P
2	0.5	Rigid	0.3	260	6.5	P
3	0.5	Rigid	0.3	260	6.5	P

Supplementary information:

10.106	TABLE: Pull-out test				P
	Model/type reference.....:			P	
No of sample	Conductor cross-sectional area (mm²)	Conductor type	Pull force (N)		
1	0.5	Rigid	20	P	
2	0.5	Rigid	20	P	
3	0.5	Rigid	20	P	

Supplementary information:

13.3	TABLE: Insulation resistance			P
	Model/type reference.....:			--
	Smallest cross-sectional area (mm ²) :	0.5		--
	Largest cross-sectional area (mm ²) :	0.5		--
Test voltage applied between		Measured (MΩ)	Required (MΩ)	
All clamping units together and the body		>100MΩ	≥5MΩ	
Each clamping unit and all others together		>100MΩ	≥5MΩ	

Supplementary information:

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



IEC 60998-1			
Clause	Requirement + Test	Result - Remark	Verdict

13.4	TABLE: Electric strength test		P
	Model/type reference.....:		P
	Rated insulation voltage (V).....:	24	P
Test voltage applied between		Test voltage (V)	Flashover / breakdown (Yes/No)
All clamping units together and the body		1250	No
Each clamping unit and all others together		1250	No
	Rated insulation voltage (V).....:	24	P
Test voltage applied between		Test voltage (V)	Flashover / breakdown (Yes/No)
All clamping units together and the body		2000	No
Each clamping unit and all others together		2000	No
Supplementary information:			

14.101	TABLE: Mechanical strength				P
	0,1 times the test current (A)..... :	2.4			--
	smallest cross-sectional area (mm ²) 10.103:	0.5			--
	force (N) (table 104):	0.09			--
	Distance (mm) (table 104):	100			--
	-screwless terminal number	1	2	3	--
	- voltage drop measured (mV) (1 st deflection) :	0.6	0.7	0.5	--
	- voltage drop measured (mV) (2 nd deflection) :	0.6	0.5	0.6	--
	- voltage drop measured (mV) (3 rd deflection):	0.7	0.6	0.6	--
	- voltage drop measured (mV) (4 th deflection) :	0.6	0.6	0.6	--
	- voltage drop measured (mV) (5 th deflection) :	0.7	0.7	0.8	--
	- voltage drop measured (mV) (6 th deflection) :	0.9	0.9	0.9	--
	- voltage drop measured (mV) (7 th deflection) :	1.1	1.2	1.1	--
	- voltage drop measured (mV) (8 th deflection) :	1.0	1.1	1.1	--
	- voltage drop measured (mV) (9 th deflection) :	1.1	1.2	1.1	--
	- voltage drop measured (mV) (10 th deflection) :	1.1	1.2	1.1	--
	- voltage drop measured (mV) (11 th deflection):	1.2	1.3	1.2	--

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com

Scan code to check authenticity



IEC 60998-1			
Clause	Requirement + Test	Result - Remark	Verdict

	- voltage drop measured (mV) (12 th deflection)	1.2	1.3	1.2	--
	- requirement: $\leq 2,5$ mV				--

Supplementary information:

Choosing the most unfavorable state to test and record.

15	TABLE: Temperature rise		P
	Model/type reference.....:		P
	Terminal.....:	<input type="checkbox"/> single <input checked="" type="checkbox"/> multiway	—
	T marking (°C).....:	<input type="checkbox"/> Yes (°C):	—
	Largest cross- sectional area (mm²).....:	0.5	—
	Conductors.....:	Rigid	—
	Rated connecting capacity (mm²).....:	0.5	—
	Test current (A).....:	6	—
Thermocouple Locations		max. temperature rise measured, (K)	max. temperature rise limit, (K)
On conductor in the terminal		26.2	45
Supplementary information: The test laboratory ambient is 25 °C.			

15.101	TABLE: Temperature-cycling test			P	
	Model/type reference..... :			P	
	Smallest cross-sectional area (mm²)..... :	0.5		P	
	Test current (Table 2) (A)..... :	6		P	
Measured voltage drop of:		Measured voltage drop (mV)			
		Sample 1	Sample 2	Sample 3	
Solid conductors (after 24 cycles)		10.4	10.4	9.7	P
Stranded conductors (after 24 cycles)		10.7	11.1	10.6	P
Flexible conductors (after 24 cycles)		10.6	11.7	9.7	P
Solid conductors (1,5 times 24 th cycle value)		11.7	12.9	13.8	P
Stranded conductors (1,5 times 24 th cycle value)		13.6	14.2	16.6	P
Flexible conductors (1,5 times 24 th cycle value)		14.1	14.0	16.5	P

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.

Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China

Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com

Scan code to check authenticity



IEC 60998-1					
Clause	Requirement + Test			Result - Remark	Verdict
Solid conductors	(after 192 cycles)	15.1	14.3	16.5	P
Stranded conductors	(after 192 cycles)	16.6	16.7	18.4	P
Flexible conductors	(after 192 cycles)	17.6	16.6	19.2	P
Supplementary information: Choosing the most unfavorable state to test and record.					

16.2	TABLE: Heating cabinet test				P
	Test temperature (°C).....:			<input checked="" type="checkbox"/> 85°C <input type="checkbox"/> T + 45	P
	Model/type reference	Sample 1	Sample 2	Sample 3	
	--	Pass	Pass	Pass	P
Supplementary information:					

16.3A	TABLE: Ball pressure test of insulating materials			P
	Test temperature (°C).....:		<input checked="" type="checkbox"/> 125 <input type="checkbox"/> T + 45 =	P
Part under test		Material designation / manufacturer	Impression diameter (mm)	
Enclosure		/	1.1	P
Supplementary information:				

16.3B	TABLE: Ball pressure test of insulating materials			N/A
	Test temperature (°C).....:		<input type="checkbox"/> 70 <input type="checkbox"/> T + 40 =	N/A
Part under test		Material designation / manufacturer	Impression diameter (mm)	
--		--	--	N/A
Supplementary information:				

17	TABLE: Clearances and creepage distances					P
	Rated insulation voltage (V).....:			24		P
	Clearance cl, creepage distance cr and distance through sealing compound tsc at/of:	Required cl, cr, tsc (mm)	Measured cl (mm)	Measured cr (mm)	Measured tsc (mm)	
	Between clamping units	≥3.0	>3.0	≥3.0	>3.0	
	Contacts-Plastic material	≥3.0	>3.0	≥3.0	>3.0	
Supplementary information:						

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
 Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street,
 Bao'an District, Shenzhen, Guangdong, China
 Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
 Scan code to check authenticity



IEC 60998-1			
Clause	Requirement + Test	Result - Remark	Verdict

18	TABLE: Glow-wire test			P
Part under test		Material designation / manufacturer	Test temperature (°C)	Time of extinguish of flames and glowing, if any
Enclosure		/	750	No flame
Supplementary information:				

19	TABLE: Tracking			P
Part under test		Material designation / manufacturer	Test voltage (V)	Remarks
Enclosure		/	175	Pass
Supplementary information:				

APPENDED TABLE					
Critical components					
Object / part no.	Manufacturer / trademark	Type / model	Technical data	Standard	Mark(s) of Conformity
Enclosure	Shenzhen Onlumi Technology Limited	WHM65-12XB-6	V-0	EN 60998-1	Tested in appliance
contact	Shenzhen Onlumi Technology Limited	--	>58%	EN 60998-1	Tested in appliance


TRF-4-S-077 A/0




Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity

**Attachment No. 1: photo documentation**

Details of: External view



Details of: External view




TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street,
Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity

**Attachment No. 1: photo documentation**

Details of: External view



Details of: External view



--- END OF REPORT ---

TRF-4-S-077 A/0



Shenzhen LCS Compliance Testing Laboratory Ltd.
Add: Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street,
Bao'an District, Shenzhen, Guangdong, China
Tel: +(86) 0755-82591330 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity